

### CITY OF REEDLEY

#### Request for Interpretation of Contract Documents

Date: 11-5-09 Time: 11:50

Company: Asphalt Maintenance Co of CA

Contact Person: Gregg Ellich

Address: 1641 E. Julian Ave Visalia CA 93292

Telephone: 627-5373 Fax: 627-6946

Plan Sheet: \_\_\_\_\_

Specification Section: 3.11

INTERPRETATION REQUESTED: Normally only Microsurfacing or SuperSlurry Seal would be applied over the Asphalt-Rubber Seal Coat. Do you want a 2 coat or 3 coat application?

REPLY: \_\_\_\_\_

(3) THREE LAYER CAPE SEAL (3 coat)

All request's and replies will be published on the City's web site at: www.reedley.com in addition to being faxed to plan holders.